



Certificate number: 2108744

Date issued 18th August 2021

Date expired 17th August 2026 Original/Amendment *Original*

Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004
Reference Standards: Regulators Specification
Model Designations: see Appendix

Manufacturer: Caleffi SpA.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification

Signed on behalf of Kiwa Watertec

David Jay,
Business Unit Manager – Authorised Signatory
Kiwa Watertec

CERTIFICATE

39017001

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate issued to:
Caleffi SpA
S.R. 229
n. 25 28010 Fontaneto d'Agogna
(NO) Italy



UK Approval Certificate (page 2 of 2)

Appendix to Certificate 2108744

502060. 502061. 501500.
SIZE: See model.
SCOPE: Manufacturer recommended maximum working pressure 10.0 bar. Maximum operating temperature 115°C. Model 501500: Maximum working pressure 10.0 bar. Maximum operating temperature 120°C. Hygienic Purposes: Non-metallic materials suitable for continuous use with closed circuits only. Above ground use only.
MATERIALS Non-metallic materials not assessed. Closed circuit use only.
BACKFLOW PROTECTION NOTES N/A.
MARKING Caleffi logo on body.
ADDITIONAL NOTES Closed circuit use only.

Extra Notes